


SIDE VIEW
NOT TO SCALE

GENERAL NOTES:

1. REFER TO THE CITY OF CONCORD SPECIFICATIONS FOR ACCEPTABLE MANUFACTURERS OF MATERIALS.
2. PROVIDE A 12" BRASS NIPPLE PAST THE WATER METER BOX.
3. WATER METER BOXES FOR 3/4" & 1" SERVICES CAN BE OF ANY MATERIAL EXCEPT CONCRETE OR METAL, MUST HAVE 2 MOUSE HOLES (2.75"W X 4"H) ONE AT EACH END OF BOX, AND HAVE A RATING OF AT LEAST TIER 15. 3/4" WATER METER BOX = 11"W X 18"L X 12"H. 1" WATER METER BOX = 13"W X 24"L X 12"H.
4. WATER METER BOX LIDS FOR 3/4" & 1" SERVICES CAN BE OF ANY MATERIAL EXCEPT CONCRETE, METAL, OR COMPOSITE, MUST CONTAIN 1 PIECE OF REBAR AT EACH END FOR LOCATING PURPOSES, NO AMR/AMI HOLE, AND HAVE A RATING OF AT LEAST TIER 15. WATER METER BOX LID FOR 3/4" SERVICE = 11.125"W X 18.1"L X 1.75"H. WATER METER BOX LID FOR 1" SERVICE = 13.75"W X 23.125"L X 2"H.
5. THE WATER METER BOX RIM & LID MUST BE FLUSH WITH FINAL GRADE. THE WATER METER BOX CAN NOT BE LOCATED WITHIN A ROAD, STREET, DRIVEWAY, SIDEWALK, OR DRAINAGE FEATURE.
6. ALL APPURTENANCES FOR THE INSTALLATION OF THE WATER METER: THE WATER METER, BRASS GROUND LOCKABLE METER CUTOFF, GASKETS, AND EXPANSION CONNECTION MUST BE INSTALLED BY THE CITY OF CONCORD IF CONNECTION IS TO AN EXISTING MAIN.
7. THE BASE OF THE WATER METER BOX MUST HAVE AT LEAST 6" TO 8" OF #57 WASHED STONE.



WATER METER
STANDARD DETAIL

3/4-INCH AND 1-INCH
RESIDENTIAL
WATER SERVICE METER

1.	11/25	By	REVISED NOTES			
No.	Date	By	REVISION			
Drawn By:		Checked By:	Approved By:	Date	Sht	of
BCC			CA/SM	11/25		