



MAIN ST. CULVERT REPLACEMENT

**PROJECT NO. 2023-024
BID NO. 2682**

ADDENDUM 3

July 21, 2025

To all bidders:

1. TREE REMOVAL AT 624 MAIN ST SW:

The Contractor shall remove the big tree closest to the creek at 624 Main St SW, as shown in the exhibit at the end of this Addendum. All costs associated with this item shall be included in Pay Item #4 – SP-02 Comprehensive Grading.

Alfred M. Brown Operations Center

635 Alfred Brown Jr. Court SW | Concord, NC 28025 O: 704-920-5425 F: 704-786-4521

concordnc.gov

2. OVERHEAD UTILITIES OVER THE CREEK AREA:

The lines visible in the picture on the poles closest to the street are communication lines, and they will remain in place during construction. There is a power line on the same poles that feeds the streetlights, which will be removed before construction starts. The power lines in the background are Duke Energy lines and will remain in place during construction. If there is concern about this line, the successful contractor can arrange with Duke Energy to sleeve these lines, providing some level of protection.




Alfred M. Brown Operations Center

635 Alfred Brown Jr. Court SW | Concord, NC 28025 O: 704-920-5425 F: 704-786-4521

concordnc.gov

PLAN

SCALE: 1" = 20'



AREA TO BE DISTURBED - 0.99 ACRES

PREPARED BY
ENGINEERING DEPARTMENT
CITY OF CONCORD
P.O. BOX 308
CONCORD N.C. 28026
(704) 920-5425



Surveyor's Seal

MAIN ST. CULVERT
REPLACEMENT
EROSION CONTROL PLAN
PROJECT # : 2032-024

[illegible]

G:\Eng\Engineering Projects\Projects\2023\024 Main St.SW Culvert\2023-024 (R-3).dwg Feb 28, 2025 - 8:28am