

## SOLICITATION NAME: LYLES LANE CIPP PROJECT

## ADDENDUM NO. 2



9/23/2025

The following are clarifications to the bid opening date and the contract documents as posted based on questions posed after the pre-bid meeting which was held on September 10, 2025:

Announcements:

1. *The bid opening has been rescheduled from **Thursday, September 25, 2025 at 2:00 PM**. It will now be held on **Thursday, October 2, at 2:00 PM**.*
2. *The question deadline due date of **Thursday, September 18, 2025 by 5:00 PM Local Time** has been extended to **Thursday, September 25, 2025 by 5:00 PM Local Time**.*

Clarifications:

1. *Would the owner consider removing the requirement of ASTM D638 tensile strength requirement of 3,000 psi found in section 33 01 30.72?*
  - a. This requirement will not be removed.
2. *How much can the deep manholes be surcharged?*
  - a. The Contractor shall be permitted to surcharge the sewer system as necessary to achieve the required hydraulic head for bypass pumping operations, provided that the surcharge water surface does not rise above a point 20 feet below the existing ground surface. Note that the Contractor shall be solely responsible for the performance of all plugs, and any consequences resulting from plug failure, including but not limited to flooding, damage to the work, or disruption of service, shall be addressed and corrected by the Contractor at no additional cost to the Owner.
3. *Will CCTV footage of the pipes to be lined with CIPP be provided?*
  - a. CCTV footage for all lines to be rehabilitated can be found at the following OneDrive link: [https://gaveldorn-my.sharepoint.com/:f/p/jkoonce/EkAnsOJcjHlJh4\\_T2yrSdaABHt6l1yBnDAfztPjDxJzQPA?e=ryceGZ](https://gaveldorn-my.sharepoint.com/:f/p/jkoonce/EkAnsOJcjHlJh4_T2yrSdaABHt6l1yBnDAfztPjDxJzQPA?e=ryceGZ)

\*\*\*\*\*

**END OF ADDENDUM NO. 2**